



235 Biesenthal Road | Pembroke | Ontario | K8A 6W7  
 www.laymanfireandsafety.com | joel@laymanfireandsafety.com  
 Phone: 613-732-5320 | Shop Phone: 613-687-2896

This information is being provided to you as a guide. The information is taken from the Ontario Fire Code.

## Maintenance Requirements: Ontario Fire Code

Daily	Check	Fire Alarm Power and Trouble light
Weekly	Check	Unsupervised Sprinkler Control Valves
	Check	Air Pressure (Dry Sprinkler System)
	Check	Fire Protection Water Supply Valves
	Test	Emergency Generator
	Check	Hoods, Filters, Ducts.
Monthly	Inspect	Portable Extinguishers
	Test	Battery Powered Emergency Lighting
	Test	Fire Alarm System
	Test	Voice Communication System
	Inspect	Standpipe Hose Cabinets
	Test	Sprinkler Alarm
Inspect	Doors in Fire Separations	
Every Two Months	Test	Sprinkler Supervisory Transmitters and Water Flow Devices
Every Three Months	Test	Elevators (High Building)
	Test	Smoke Control Measures (High Buildings)
	Conduct	Fire Drill (High Buildings)
Every Six Months	Test	Sprinkler Supervisory Devices
	Service	Fire Protection for Commercial Cooking Equipment
	Service	Emergency Generator
	Inspect	Elevators in Smoke Shaft (High Buildings)
Annually	Inspect	Venting to Aid Firefighting (High Buildings)
	Inspect	Air Handling Systems (High Buildings)
	Inspect	Fire Dampers and Fire Stop Flaps
	Inspect	Chimneys and Fluepipes
	Inspect	Disconnect Switches - Air Handling Units
	Clean	Incinerator Spark Arresters
	Inspect	Fire Hydrants (On Private Property)
	Service	Portable Extinguishers
	Test	Battery Powered Emergency Lightning
	Test	Fire Alarm System
	Test	Voice Communication System
	Inspect	Standpipe System
	Service	Emergency Generator
	Conduct	Fire Drill
Every Two Years	Service	Emergency Generator
Every Three Years	Service	Emergency Diesel Generator
Every Five Years	Service	Emergency Generator (Windings)
Every 15 Years	Inspect	Dry Sprinkler System (Obstructions)